

HAZARDOUS AREA SCHEDULE

REFER TO AS/NZS 60079.10.1 - 2009

AREA	ZONE	DESCRIPTION	SIZE
A	1	TANK VENT	1.5M SPHERE FROM VENT OUTLET
B	2	TANK VENT	1.5M RADIUS AROUND PIPE
C	2	TANK FILL POINT	4M RADIUS FROM FILL POINT / 1M ABOVE GROUND
D	2	TANK DIP POINT	4M RADIUS FROM FILL POINT / 1M ABOVE GROUND
E	1	FUEL DISPENSER	HYDRAULIC COMPARTMENT OF DISPENSER CABINET 1M LATERALLY FROM DISPENSER / 0.25M ABOVE GROUND
F	2	FUEL DISPENSER	5M MIN. FROM DISPENSER / 0.5M ABOVE GROUND 0.5M FROM DISPENSER / 1.2M ABOVE GROUND TO 0.5M ABOVE GROUND
S	2	LPG BOTTLE CABINET	0.5M FROM CABINET / 0.5M ABOVE CABINET TO 1.5M FROM AT MID HEIGHT OF CABINET TO GROUND
T	2	ALL UNDERGROUND FITTINGS DRAINING A HAZARDOUS AREA.	0.5M FROM DRAIN / 0.3M ABOVE DRAIN
U	1	ALL UNDERGROUND FITTINGS DRAINING A HAZARDOUS AREA.	THE AREA WITHIN COLLECTION DRAINS, SUMPS

